

**To**

**M/s. Scon Infra Prestress LLP,**  
17, Matru Ashish CHS Ltd.,  
Opp. Azara bank, Gorai-II,  
Plot no. SC - 5, Rsc - 52,  
Borivali (W) - 400092  
[info@scoinfra.com](mailto:info@scoinfra.com)

**Sub: Regarding Vendor approval to M/s. Scon Infra Prestress LLP.**

**Ref:** Hon. MC order No. MMRDA/Material/Approval/Committee/Rev/128 dtd.  
05/09/2023 & Revised order dtd. 08/11/2023

Dear Sir,

Your firm Scon Infra Prestress LLP has submitted the letter in MMRDA on date 06/06/2024 for your product Bridge Expansion joints (single Stripseal, Modular Expansion Joint), Architectural Expansion joints in Buildings.

Your product Bridge Expansion joints (single Stripseal, Modular Expansion Joint), Architectural Expansion joints in Buildings are in principle approved for One year with following terms & conditions;

- 1) The product should be proposed by the Concern Head of Department. The product should be proposed only if it is better than existing prevailing used product.
- 2) The product shall be finally approved from respective site consultant in conformity with requirements of specifications of Bureau of Indian Standards, applicable code provisions, etc.
- 3) The In principle approval has been granted on the basis of documents/information furnished by you. The approval would be cancelled if any details are found in variance to the details already furnished during the inspection of manufacturing unit.

MMRDA reserves the right to visit the manufacturing unit at any time.

- 4) MMRDA is not bound to give you any priority or preference in the issue of enquiry and placement of purchase order and does not guarantee all or any of the enquiries for the above items would necessarily be sent to you.

मुंबई महानगर प्रदेश विकास प्राधिकरण

वांद्रे-कुर्ला संकुल, वांद्रे (पूर्व), मुंबई 400049.

दू +91 22 2649 9238 ईमीएमीएस +91 22 2649 0009 / 4000 फॉ +91 22 2649 9992 / 9264  
<https://mmrda.maharashtra.gov.in>

- 5) The applicant shall arrange for visit of MMRDA Engineers/Committee members for inspection of sites, where the products are used/being used, at its own cost, as and when requested by MMRDA.
- 6) The Change in Postal address, contact Phone No., Fax No., in the Constitutions or working of your firm, if any, to be intimated to this office immediately.
- 7) During the period, the applicant's request for defective material shall be attended by the vendor free of cost within a month's time from date of complaint wherever arises should be give in undertaking.
- 8) The product shall be used only on Pilot basis. After its use and found suitability it should be referred again to committee for as permanent use.
- 9) If your company shall improve product value by acquiring additional quality accreditations and/or achieves better performance, then such changes shall be invariably informed to this office.
- 10) This approval will be renewed further on request of the firm & depending upon the performance of product on MMRDA works after feedback from respective sites where the product is used.
- 11) MMRDA reserves the right to revoke/cancel the approval, without assigning any reason.

Yours faithfully,



(Basavraj Bhadragond)  
Engineer-In-Chief



## CITY AND INDUSTRIAL DEVELOPMENT CORPORATION OF MAHARASHTRA LIMITED

(CIN - U99999 MH 1970 SGC - 014574)

CIDCO/EE (UCR)/2025/ 912

23.06.2025

To,

M/s. J. Kumar - J. M. Mhatre (JV),  
16A, Andheri Industrial Estate.  
Veera Desai Road, Andheri (W),  
Mumbai- 400053.

Name of Work: Design & Construction of Coastal Road from Amra Marg to MTHL Junction  
(from CH 00 at Amra Marg to CH 2900) including Airport Link Road (from CH 00 to CH 903) at Navi Mumbai.

CA. No : 02/CIDCO/SE (K, U & D)/EE (UL-III)/2018-19

Ref- 1. Your letter KJIL-JMM/CIDCO/COASTAL-R1/2025/934 dated 10.06.2025

Dear Sir,

With reference to above, you have requested for approval of vendor **M/s. SCON Infra Prestress LLP** for supply of Strip Seal Expansion Joint . The product has been approved for the work of Design and construction of 11.0m wide Bye-Pas Bridge with approaches from Hotel Anandi to Uran City in Dronagiri, Navi Mumbai as a **Project Specific Approval**.

Since the product is approved as Project Specific Approval . it is necessary to register the vendor in CIDCO Ltd .

You are therefore requested to intimate the vendor **M/s SCON Infra Prestress LLP** for necessary registration in CIDCO Ltd .

Thanking You.

Yours faithfully,

(M M Munde)

EE (Ulwe Coastal Road)  
6<sup>th</sup> Floor, CIDCO Bhavan,  
CBD-Belapur, Navi Mumbai.

## CITY AND INDUSTRIAL DEVELOPMENT CORPORATION OF MAHARASHTRA LIMITED

(CIN - U99999 MH 1970 SGC - 014574)

**REGD. OFFICE:**

"NIRMAL", 2nd Floor, Nariman Point,  
Mumbai - 400 021.  
PHONE : 00-91-22-6650 0900  
FAX : 00-91-22-2202 2509

**HEAD OFFICE:**

CIDCO Bhavan, CBD Belapur,  
Navi Mumbai - 400 614.  
PHONE: 00-91-22-6791 8100  
FAX : 00-91-22-6791 8166

*Ref. No.*

*Date :*

CIDCO/EE(Dron-I)/2025/331

15.05.2025

To,  
M/s J.M. Mhatre Infra Pvt. Ltd.,  
Plot No. 492, Market Yard,  
Sahakar Nagar,  
Panvel-410206.

Sub: Design and construction of 11.0 m wide Bye-pass Bridge with approaches  
from Hotel Anandi to Uran City in Dronagiri, Navi Mumbai.

C.A. No. 05/CIDCO/EE(Dron-III)/2016-17.

Ref: (1) Work Order No. CIDCO/EE(Dron-III)/2017/1209 dated 27.11.2017  
(2) Agency letter No. JMMIPL/CIDCO/2025/06 dated 11.02.2025

Dear Sir,

This is to inform you that, your request vide letter dated 11.02.2025 regarding approval  
to use the material 'Strip Seal type Expansion Joints' of vendor 'M/s SCON Infra Prestress  
LLP' has been accorded by the Competent Authority of CIDCO as a **Project specific  
approval**.

In view of above, you are requested to take the note of the same and procure the above  
said material at the earliest to be used for this work.

This is for your information and further necessary action.

Thanking you,

Yours faithfully,



Executive Engineer (Dron-I)  
CIDCO Nodal Office, Sector-14,  
Bokadvira, Dronagiri, Navi Mumbai-400 707.

Ref. No: Bloom CMC/Chiplun/Pac. II/2025/2128

Date: 28/06/2025

To,  
**The Project Manager,**  
**Parshuram Arawali Highway Private Ltd.**  
**Survey No. 1523, Mumbai-Goa Highway,**  
**Vill - Kamate, Tal - Chiplun, Dist - Ratnagiri-415605**

**Subject:** Independent Engineer Services for rehabilitation and up-gradation of NH-66 (Old NH 17) from Km 205/400 to 241/300 (Parshuram Ghat - Arawali Section) to four lanes in the State of Maharashtra under NHDP-IV on Hybrid Annuity Mode (Package-II):- "Submission of credential of SCON Infra pre-stress LLP for Expansion joint and Elastomeric Bearing" - Reg.

**Ref:- 1) Letter No PAHPL/HAM/2025/1803 dated 23/06/2025.**

Dear Sir,

With reference to subject and letter cited above proposal received regarding credential of M/S SCON Infra Pre-stress LLP for Expansion joint and Elastomeric Bearing for chiplun flyover. IE has reviewed the credential and found in order.

The further approval shall be given after conducting factory visit and regular lot test of bering as per provision and guideline given in MoRTH section 2000 and as per IRC 83; 2018 part II and of expansion joint as per MoRTH Circular, witness inspection of manufacture unit, conducting the test requirement as per IRC SP-69.

This is for your information and necessary action please.

**Thanks & Regards,**  
**For, Bloom Companies, LLC USA in Association with**  
**Credible Management Consultant Pvt Ltd.**  
**Chiplun, Dist-Ratnagiri**



Sanjeev Rai

**Acting Team Leader cum Resident Engineer**

- CC: 1) Executive Engineer, National Highway Division (PWD) Ratnagiri for information.**
- 2) Sub-divisional Engineer, National Highway Division, (PWD), Chiplun for information**
- 3) H.O. Bloom Companies, LLC, Sohna, Gurgaon (Haryana) for information.**



# L.N. MALVIYA INFRA PROJECTS PVT. LTD.

Registered Office : Plot No. 29, F/F Sector-11, Dwarka, New Delhi - 110078

Corporate Office : T-10, 111rd Floor, City Centre, Press Complex,

Plot No. 1, M.P. Nagar, Zone-I, Bhopal (M.P.) 462011,

Tel./Fax : 0755 - 4295421

CIN No. : U45201DL2010PTC373715

Mob.: 9826452711, 7773000871, 9977004686, 9617777944 | E-mail : lnmalviya@rediffmail.com | Web. : www.lninfra.com

Ref No: LNMIPPL/TBPL/Sidhi-Singrauli/2022-23/ 2489

Date: 13-08-2022

To,  
The Project Manager,  
Tirupati Build-con Private Ltd.,  
Sidhi-Singrauli Road (M.P.)

**Sub:** Authority Engineering Services for Balance work of rehabilitation and up-gradation of Sidhi-Singrauli from Km 82.400 to Km 187.993 section of NH-39 (Old NH-75E) (Designed Length 105.593 Km) to four lane with paved shoulder in the state of Madhya Pradesh on EPC mode under NH (O). Reg: -“Review of Drawing for strip seal expansion joint”.

**Ref:** Your Office Letter No. TBCL/22-23/NH-75/ Sidhi-Singrauli/178, dated 27.07.2022.

**Sir,**

Reference to above, the Drawing of strip seal expansion joint at CH. 156.958/001 for the above said Project received through email as listed below have been reviewed and seems to be in order.

S. No.	Drawing No.	Drawing Title	Rev. No.
1.	HBS/NH75E/ROB/CH: 156.958/001	STRIP SEAL EXPANSION JOINT	R0

Thanking you and assuring of our best services always.

Yours Truly,  
For, L.N. Malviya Infra Projects Pvt. Ltd.

(Authorized Signatory)

**Copy to:**

1. The Chief Engineer (BOT), MPRDC, 45-A, Arera Hills, Bhopal (MP) for information please.
2. The Divisional Manager, MPRDC, Dist. Sidhi (MP) for information please.

Ref No:- AE/TES/FAGNE-MAH-GUJ BORDER(NH-6/53)/2022/508 Date:- 28/11/2022

To,  
**M/s. J. M. Mhatre Infra Pvt. Ltd.**  
 Plot No. 22, Kalyani Nagar,  
 Behind SaptashrungiMangalKaryalaya,  
 Surat Bypass Road,  
 Dhule, Maharashtra.  
 Tel.No.07506418605  
 Email:jmmiplnh6@gmail.com,jmmipl@jmmipl.in

**Subject :-** Balance works of 4 - laning of FagnetoMah-Guj Border Section of NH-6 in the state of Maharashtra from km. 510.000 to km. 650.794 (design length 140.794 km) under Bharatmala Pariyojna on Engineering, Procurement, Construction Mode -Approval of Source for Expansion Joints-Reg.

**Ref:-**(i)Your Letter No. JMMIPL/AE/Fag-Mah-GujBor/NH-6/2022-23/933, Dtd. 11.11.2022.  
 (ii) Your Letter No. JMMIPL/AE/Fag-Mah-GujBor/NH-6/2022-23/752, Dtd. 12.05.2022.

**Dear Sir,**

With ref. to the letters cited above and joint visit conducted for Testing & Inspection of Expansion Joints at M/s. SCON Infrastructure Pvt. Ltd., Bhiwandi, Dist. Thane.

Following test carried out in presence of Team Leader .

1-Loop Anchorage Test

2- Pounding Test

3-Cyclic Motion Test

The test results conforms to specification & standards as per relevant IS Code and are found satisfactory.

In view of above M/s. SCON Infrastructure Pvt. Ltd., Bhiwandi, Dist. Thane, is approved as source of Expansion Joints.

Thanking you and assuring you our best services.

Regards  
 Theme Engineering Services Pvt. Ltd.  
 Nagendar Rai  
 (Team Leader)

**Copy to :** PD, NHAI PIU- Dhule

**Encl :** Test results



Report No.: SCON/22-23/EXPJ/01  
Date: 19.11.2022  
Test : Strip Seal Expansion Joints

**Single Strip Seal Expansion Joints**

Client :	J. M. Mhatre Infra Pvt. Ltd.
Consultant :	<b>Theme Engineering Services Pvt. Ltd.</b>
Project :	Fagne-Mah/Guj Border Section of NH-6 in State of Maharashtra from Km 510+000 to Km 650+794 (140.794 Km).
Manufacturer:	M/s. SCON INFRASTRUCTURE
Anchorage Type :	Loop Anchorage
Movement:	80mm
Test Specification:	IRC-SP-69-2011

Above mention Single Strip Seal Expansion Joint System is tested.

Test performed by -

  
19.11.2022

Tushar Gaonkar  
QA Engineer



	Scon Infrastructure	Consultant
Sign		<b>Theme Engineering Services Pvt. Ltd.</b>
Date	 N.K Bassi	 Nagendra Rai
Name	( V.P Scon Infrastructure)	(Team Leader)



Report No.: SCON/22-23/EXPJ/02  
Date: 19.11.2022  
Test: Strip Seal Expansion Joints

Client : J. M. Mhatre Infra Pvt Ltd.  
Consultant : Theme Engineering Services Pvt. Ltd.

Performance Evaluation test:  
Standard : IRC-SP-69-2011

Clause no.: 8.3.2.1

#### CYCLIC MOTION

Cyclic Motion test is carried out once on one meter sample piece selected at random from lot.

Test Movement :	95 mm	Any sign of Distress
No. of Cycles:	5 cycles	No

Result : No sign of distress on Strip seal or edge beam was found Satisfactory.

Clause no.: 8.3.2.2

#### PONDING

Water is ponded along one meter length of joints.

Test :	Leakage Found
The depth of water shall not fall below 25mm anytime during test.	No
A close inspection of underside of joint shall not reveal any leakage.	

Result : No Leakage found from seal and found Satisfactory.

  
19.11.2022

Test performed by -

Tushar Gaonkar  
QA Engineer

	Scon Infrastructure	Consultant Theme Engineering Services Pvt. Ltd.
Sign		
Date	 N.K Bassi (V.P Scon Infrastructure)	 Nagendra Rai (Team Leader)
Name		



Report No.: SCON/22-23/EXPJ/04  
 Date: 19.11.2022  
 Test: Strip Seal Expansion Joints

Standard : IRC-SP-69-2011

**Anchorage Pull out test**

Clause no.: 8.2.1

J. M. Mhatre Infra Pvt Ltd.

Consultant : Theme Engineering Services Pvt. Ltd.

The Steel Profile Shall Be Anchored to the desk By Plate loop anchorage.

The minimum thickness of Loop shall be 12 mm & spacing shall not exceed 250 mm.

In F type Single Strip Seal Joint System No. Of Anchorage Provided in 1 Meter of Length are 5 Nos.

As the spacing of anchorage is about 200mm.

So each anchorage has to resist about more than 120 Kn of Force.

Type of Test	Anchorage Pull out Test	
<b>Minimum Force Required to Resist</b>	<b>120</b>	<b>KN</b>
Vertical Ram Area	190.8	cm.sq
Test Load (Specified)	12.23	Ton
Pressure Gauge Reading (Specified):-	64.11119	Kg/cm.sq
Test Load (Applied)	13.356	Ton
Pressure Gauge No.	18	
Pressure Gauge Reading (Applied):-	70	Kg/cm.sq
<b>Force (Applied)</b>	<b>131.0224</b>	<b>KN</b>
Duration of Load:-	10	
No. Of Joint Sample	1	nos.
Force applied on one meter will be	524.0894 KN	

**HENCE THE ABOVE ANCHORAGE SYSTEM SATISFIES THE ULTIMATE RESISTANCE**

  
19.11.2022



Test performed by -

Tushar Gaonkar

QA Engineer

Consultant  
**Theme Engineering Services Pvt. Ltd.**

Sign	Scon Infrastructure	
Date	N.K Bassi ( V.P Scon Infrastructure)	 Nagendra Rai (Team Leader)
Name		



Certificate No.  
TC- 7879

Format No. SAS/QF/05.09.27 a,b



**Sohm**  
Analytical

**Sohm Analytical Services (I) Pvt Ltd.**  
CIN No.: U74900MH2015PTC266186  
A-101/121, B-33/35, Amargian Industrial Estate,  
Pokharan Road No.1, Opp. S.T. Work Shop,  
Khopat, Thane (West) - 400601  
Tel No.: + 91 22 2547 12 97 / 93 / 94  
Cell No.: + 91 7303790999  
Telefax No.: + 91 22 2547 12 95  
Email : thane.support@sohmanalytical.com  
Web.: www.sohmanalytical.com

## TEST REPORT

**M/s SCON INFRASTRUCTURE**  
Building C/2, Prithvi Complex, Kalher, Bhiwandi

Ref. No.: SC-TC-14  
Challan Dated: 29-07-2022

ULR-TC787922000016244F

Lab Ref. No.: Z4736R

Sample Received on: 01-08-2022

Report Completed on: 06-08-2022

Stamped By:

Specification: IS 2062:2011 Gr. E250 QUALITY  
BR

**Description:** Testing of Test Piece Sample

Size

Ref. ID 148

Description Expansion Joint (F Section)

Discipline : Chemical Group : Metals & Alloys

CHEMICAL ANALYSIS BY SPECTRO (OES) Test Method : ASTM E 415 -2021

Eqpt. Sr. No: 18006596

Elements	Result	Required Value
% Carbon	0.18	0.22 max.
% Silicon	0.27	0.40 max.
% Manganese	0.51	1.50 max.
% Phosphorus	0.045	0.045 max.
% Sulphur	0.034	0.045 max.
% Chromium	0.17	
% Nickel	0.072	
% Molybdenum	0.020	
% Copper	0.099	
% Vanadium	0.010	
% Aluminium	0.004	
% Carbon Equivalent	0.32	0.41 max.

**Remarks: THE ABOVE MATERIAL CONFORMS TO IS 2062:2011 Gr. E250 QUALITY BR WITH RESPECT TO ELEMENT ANALYSED.**

Discipline : Mechanical Group : Mechanical Properties of Metals

Hardness Test Test Method : IS 1500 PART 1:2019

Eqpt. Sr. No: 2011/144 Calibration Date: 02-09-2021 Due On: 01-09-2022

Description	Result
Location	Surface
Hardness	2.5 mm dia ball / 187.5 Kgf Load
Hardness In HBW	150,153,150

Note : TC Revised on Dtd. 06-08-2022 Due to Specification Change.

-----End of Report-----

FOR SOHM ANALYTICAL SERVICES (I) Pvt Ltd.

Deepali Mhatre  
Authorised Signatory

Deepali Mhatre  
(Sr. Chemist)

Pawan Singh  
Authorised Signatory

Pawan Singh  
Sr. QC Engg-Mech



Shweta  
Checked by

Notes:

- The above test reports relate only to sample submitted.
- Sample shall not be drawn by Sohm Analytical Services (I) Pvt Ltd.
- No part of this test reports may be reproduced without the written permission of the QM.
- The company or its directors shall not be responsible in any way for any financial liability due to omission or error made in the report.
- Accredited as per ISO/IEC 17025 : 2017 by NABL.



**ABP MANUFACTURING CO.**  
**MANUFACTURERS OF: PRESSURE GAUGES**  
**AN ISO 9001:2015**



213/Bharat Industrial Estate, Besides. Corpora, Nr. Asian Paints L.B.S. Marg, Bhandup(W), Mum-400 078  
 Off-022-2595 8280, Tele fax- 022-2595 8280 Mob-97698 82430

Website-[www.abpmanufacturing.com](http://www.abpmanufacturing.com) Email- [info@abpmanufacturing.com](mailto:info@abpmanufacturing.com) [abppressuregauges@gmail.com](mailto:abppressuregauges@gmail.com)

**CALIBRATION CERTIFICATE [ABP/CERT/RI/S/2022]**

Client :- M/s. SCON INFRASTRUCTURE		Date : 07-10-2022
Instrument No.:- <b>032</b>	MAKE :- ABP	Specified Accuracy:±1.6 %of FSD
Dial Size :- 4"DIAL		Range : 0 – 700kg/cm <sup>2</sup>
Connection: 3/8"BSP/ Bottom	Element : Complete SS, Glycerin Filled	Type : HYDRAULIC
Gauge Reading IN KG/CM <sup>2</sup>	Master Gauge Reading UP IN KG/CM <sup>2</sup>	Master Gauge Reading DN IN KG/CM <sup>2</sup>
0	0	0
100	100	101
200	201	202
300	302	303
400	404	405
500	506	507
600	607	608
700	708	-

The above Pressure Gauges are traceable to Master Gauge 0-1000KG/Cm<sup>2</sup> Test Gauge SR NO. 224184-7-1  
 This is to certify that the above Pressure Gauges is within specified Accuracy as per IS -3624 1987

Warranty : The Pressure gauges carry a limited warranty for calibration for a period of **6 Months** from the date of calibration.

For ABP Manufacturing Co.



(Q.C. Dept.)







## CITY AND INDUSTRIAL DEVELOPMENT CORPORATION OF MAHARASHTRA LIMITED

(CIN - U99999 MH 1970 SGC - 014574)

Ref. no. CIDCO/ EE (PA & R)/ P-2947/ 2025/521

Date: 26.08.2025

To

**M/s SCON Infra Prestress LLP,**

Regd. Office

Shop no. 17,

Gorai Matruaashish CHS Ltd.,

Opp. Azara Bank Gorai II, Borivali (W)

Mumbai, Maharashtra -40092

Factory Unit

H. No. 2991, Babosa Industrial Complex,

Nashik Highway,

Sarvali village,

Bhiwandi -421302

Contact Person: Shri. Umesh Hari Bhujbalrao

Contact no. - +91 93245 16701

E-Mail Id- info@sconinfra.com

**Sub: Registration as an Approved Vendor**

Ref: Your application vide file no P-2947 received on 24.06.2025

Dear Sir,

With reference to your request /application on subject matter, we are pleased to inform you that, your registration as an approved vendor for our projects / works for the following products is approved herewith for a period of **Two (02) years** from date of issue of this certificate i.e. **26.08.2025 to 25.08.2027**.

Sr. No.	Material Description	Material/Size/Range/Type/Specification
1	Civil Items-Bridge Bearings And Expansion Joints	1. POT/PTFE Bearing 2. Pre-Stressing System/ Prestressing Materials 3. Expansion Joints 4. HDPE Pipes



*Shrikant*  
Executive Engineer (PA & REG.)  
CIDCO Ltd.

Regd. Office: Nirmal, 2nd Floor, Nariman Point, Mumbai - 400 021 • Tel.: 022 6650 0900  
Head Office: CIDCO Bhavan, CBD Belapur, Navi Mumbai - 400 614 • Tel.: 022 6791 8100


Page 1 of 2

Kindly note that,

- a) The validity of this enlistment is valid for **Two (02) Years** i.e. from **26.08.2025** to **25.08.2027**. However, the Corporation reserves the right to cancel the same in case complaints are received from users within that period.
- b) The product shall be in conformity with requirements of BIS/ISO Standards. You shall keep your BIS/ISO registration valid and any changes in the same shall be intimated to this office.
- c) The approval has been granted on the basis of documents/information furnished by **M/s SCON Infra Prestress LLP**. The approval would be cancelled if any details are found in variance to the details already furnished during the inspection of manufacturing unit. Further CIDCO Ltd. reserves the right to visit the manufacturing unit at any time.
- d) It is a responsibility of user to ascertain quality and safety associated with product before acceptance, capacity of vendor for supply schedule, to carry out all tests as per relevant IS codes, past & present supply performance of various contractors in Mumbai & Navi Mumbai. Further inclusion in the approved list does not absolve the users from acceptance of bad quality of product.
- e) The registration shall not bind CIDCO Ltd. to give you any priority or preference in the issue of enquiry and placement of purchase orders and does not guarantee that all or any of the enquiries for the above items would necessarily be sent to you.
- f) You are also required to intimate us the changes, if any, in the postal address, the contact Phone Number, Fax Nos. in the constitutions or working of your firm during the currency of registration of your firm with us.
- g) You are required to apply 60 days in advance for revalidation before expiry of current validity of enlistment along with all documents and information as required.
- h) During the period of enlistment, if, your company **M/s SCON Infra Prestress LLP** improves your product value by acquiring additional quality accreditation and/or achieves better financial performance then such changes shall be invariably informed to the Corporation.
- i) You shall share the copies of invoice with prices of the orders placed for works of CIDCO Ltd., if required.
- j) If a contractor working for CIDCO Ltd. works place purchase order for the material, the same will have to be supplied on priority, adhering time schedule required by CIDCO, failing which CIDCO Ltd. may cancel the registration of product which may please be noted.

Thanking you,

Yours faithfully,

  
(V. Y. Ingle) 26/8/2025

Executive Engineer (PA & Reg.),  
CIDCO Ltd, 3<sup>rd</sup> Floor, CIDCO Bhavan,  
CBD Belapur, Navi Mumbai -400 614  
Contact No.: 022 – 6791 8300  
E-mail : ee.pa-reg@cidcoindia.com



Ref: JKIL/ JNPTPkg-01/SI/PO/26/2025-26/Amd-01

Date: 05.07.2025

## PURCHASE ORDER (Amendment-01)

M/s. SCON INFRA PRESTRESS LLP

1st Floor/ T-5, Office No. No.111

Swastik Regalia Apartment

Wagbil Road, Thane West

Maharashtra -400607

Email: [factory@sconinfra.com](mailto:factory@sconinfra.com) ; [p.singhbaghel@gmail.com](mailto:p.singhbaghel@gmail.com)

Kind Attn.: Mr. Prashant Singh (+91 7440909256)

Project: JNPT Pkg 1, Navi Mumbai, Maharashtra

Subject: Amendment Purchase Order for Supply and installation of Rubber seal for Strip Seal Expansion Joint for above project.

### Reference:

- 1) Your Offer Date: 02/06/2025.
- 2) Original order ref: JKIL/ JNPTPkg-01/SI/PO/26/2025-26, Date: 07.06.2025

Dear Sir,

With reference to above, we are pleased to issue this amendment Purchase order for the above subject work as per broad Terms & Conditions detailed below.

Amended order Value: Rupees **27,25,800.00/-** (In Words: **Rupees Twenty- Seven Lakh Twenty-Five Thousand Eight Hundred Only**) Including GST@18% revised from original order value: Rupees **11,89,440.00/-** Including GST@18% as per attached BOQ (Annexure-1)

All other terms and conditions will remain same as per original work order ref: JKIL/ JNPTPkg-01/SI/PO/26/2025-26, Date: 07.06.2025

Please return the acknowledgement copy within Two (02) days of date of issue of this order duly signed and stamped on each page, as token of supplier's acceptance along with all Terms & Conditions without any conditional statements. In the event the order acceptance

Nirmal  
05-07-25.



is not received within the above specified time, the subject order shall be deemed to be accepted by the supplier.

This Amendment order will be effective from date of this amendment order i.e 05-07-2025

Thanking you,

Yours Faithfully,

For M/s. J.Kumar Infraprojects Ltd.



Authorised Signatory

Accepted by  
For M/s SCON INFRA PRESTRESS LLP

Authorised Signatory

Annexure-01 BOQ											
Original Order Ref: JKIL/ JNPTPkgs-01/SI/PO/26/2025-26, Date: 07.06.2025				Amendment-01 Differential Amount							
Srno	Description	Unit	Quantity	Rate	Amount	Quantity	Rate	Amount	Quantity	Rate	Amount
1	Supply & Installation of rubber seal for Strip seal expansion joint.	RMT	720.00	1,400.00	10,08,000.00	930.00	1,400.00	13,02,000.00	1,650.00	1,400.00	23,10,000.00
	<u>Total Basic</u>				<u>10,08,000.00</u>			<u>13,02,000.00</u>			<u>23,10,000.00</u>
	<u>Transportation</u>					<u>Inclusive</u>					<u>Inclusive</u>
	<u>Add @ 18% GST</u>				<u>1,81,440.00</u>			<u>2,34,360.00</u>			<u>4,15,800.00</u>
	<u>Total After GST</u>				<u>11,89,440.00</u>			<u>15,36,360.00</u>			<u>27,25,800.00</u>

In Words: Rupees Twenty- Seven Lakh Twenty-Five Thousand Eight Hundred Only

